

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 396/25

Date: 17-06-2025

It is certified that an inspection team headed by **DR. RUDRESH.G MEDICAL OFFICER**, from **MALLATHAHALLI PRIMARY HEALTH CENTRE, MALLATHAHALLI, BANGALORE - 560056**, inspected the **IMPERIAL SCHOOL, SURVEY NO. 224/2 & 226/2, SALAHUNASE VILLAGE, UDAYAPURA POST, NEAR KAGGALIPURA MAIN ROAD, BENGALURU - 560082** and on the basis of Water Test Report (Attached) bearing No. 004 dated 11-06-2025 of **RURAL DRINKING WATER AND SANITATION DEPARTMENT, BANASHANKARI, BENGALURU URBAN, BENGALURU - 560070 (PHED Lab)** certified that the **IMPERIAL SCHOOL** has safe drinking water facilities for the students and members of staff of the institution. School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till **ONE YEAR**.

Signature with Seal:

*Medical Officer
Primary Health Center.
Mallathahalli, Bangalore*

Name: **DR. RUDRESH.G**

Designation: **MEDICAL OFFICER**

Name & Address of the Office / Department:

**Mallathahalli Primary Health Centre,
Mallathahalli, Bangalore - 560056.**

To,
**IMPERIAL SCHOOL,
SURVEY NO. 224/2 & 226/2,
SALAHUNASE VILLAGE,
UDAYAPURA POST,
NEAR KAGGALIPURA MAIN ROAD,
BENGALURU - 560082**

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK
Bengaluru Urban Divisional Laboratory-Banashankari, Bangalore-560070.
NABL Accredited Laboratory Bangalore urban

TEST REPORT

Address of the sampling location :- IMPERIAL SCHOOL

Report date: 11/06/2025

Report Number: 0004

Reference: TRF

Sample code: 0004

Date of Sample collection: 09/06/2025

Analysis start date: 10/06/2025

Analysis completion date: 10/06/2025

Sample quantity: 1 Liter

No.224/2 & 226/2, Saluhunase, Kaggalipura

Kanakapura Main Road, Bangalore-560082

Sample Particulars: R.O water

Sl. No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
Description: Colourless liquid					
1	pH Value @25°C Temp	6.9	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 2022
2	Specific Conductance, $\mu\text{S}/\text{cm}$ @25°C Temp	200	-	-	IS 3025 (Part-14) : 2013
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6):2018
4	Colour, Hazen Units	< 1.0	5	15	IS 3025 (Part-4) :2021
5	Turbidity, NTU	0.0	1	5	IS 3025 (Part-10) : 2023
6	Total Dissolved Solids, mg/l @180°C	120	500	2000	IS 3025 (Part-16) : 2023
7	Alkalinity as CaCO_3 , mg/l	21.5	200	600	IS 3025 (Part-23) : 2023
8	Total Hardness as CaCO_3 , mg/l	60.1	200	600	IS 3025 (Part-21) : 2009
9	Calcium as Ca, mg/l	11.2	75	200	IS 3025 (Part-40) : 1991
10	Magnesium as Mg, mg/l	7.8	30	100	IS 3025 (Part-46) : 2023
11	Chloride as Cl, mg/l	18.7	250	1000	IS 3025 (Part-32) : 1988
12	Sulphate as SO_4 , mg/l	17.8	200	400	IS 3025 (Part-24) : 2022
13	Fluoride as F, mg/l	Nil	1	1.5	APHA 24 th Edition
14	Nitrate as NO_3 , mg/l	1.2	45	No relaxation	APHA 24 th Edition
15	Iron as Fe, mg/l	Nil	1	No relaxation	IS 3025 (Part-53) : 2003

Remark: The above given sample conforms to the acceptable limits as per IS 10500:2012 drinking water specifications for the above mentioned parameters only.

Analysed by: *Megha K.S*
Senior Analyst/Junior Analyst

Authorized Signatory: *Pavithra B.S*
Technical Manager: Pavithra B.S



RDWSD/WQMSP/TeR/01

Note:

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01

---END---